

Loading Comparison				
Permittee and Parameter	Criteria end-of-pipe concentration at 1999 design flow (lb/day)		Actual Loads 2006 – 2011 (lb/day)	
	Average Monthly Limit	Maximum Daily Limit	92 nd Percentile ¹	Maximum
C d'A Cadmium	0.032	0.056	0.0026	0.0063
PF Cadmium	0.010	0.030	0.0019	0.014
HARSB Cadmium	0.0049	0.014	0.00061	0.00147
C d'A Lead	0.18	0.39	0.024	0.078
Coeur d'Alene 1999 Permit Before 2004 Modification			Actual Loads 2006 – 2011 (lb/day)	
	Average Monthly Limit	Maximum Daily Limit	92 nd Percentile ¹	Maximum
C d'A Lead	0.13	0.29	0.024	0.078

Notes:

1. The 92nd percentile is provided as an estimate of the maximum monthly average load (i.e., what can be achieved 11/12^{ths} of the time).